

ESL-TR-90-324

## **PASSIVE PIEZOELECTRIC HYDROGEN CHLORIDE MONITOR**

---

Ahmad Suleiman, Marie Pender, George Guilbault

Universal Sensors, Inc.  
5258 Veterans Blvd, Suite D  
Metairie, LA 70006

Contract No. F08635-89-C-0346

January 1990

**DISTRIBUTION A:** Approved for public release; distribution unlimited.

## **ENGINEERING SERVICES LABORATORY**

■ Air Force Engineering & Services Center

■ Tyndall Air Force Base, FL 32403-5323

## **DISCLAIMER**

Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not constitute or imply its endorsement, recommendation, or approval by the United States Air Force. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Air Force.

This report was prepared as an account of work sponsored by the United States Air Force. Neither the United States Air Force, nor any of its employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights

This document is submitted as an historical record of work performed. Limitations of the available media rendered editing impractical; therefore it is retained "as is."

## REPORT DOCUMENTATION PAGE

Form Approved  
OMB No. 0704-0188

1a. REPORT SECURITY CLASSIFICATION Unclassified			1b. RESTRICTIVE MARKINGS		
2a. SECURITY CLASSIFICATION AUTHORITY			3. DISTRIBUTION / AVAILABILITY OF REPORT Approved for public release; distribution unlimited.		
2b. DECLASSIFICATION / DOWNGRADING SCHEDULE			5. MONITORING ORGANIZATION REPORT NUMBER(S)		
4. PERFORMING ORGANIZATION REPORT NUMBER(S)			7a. NAME OF MONITORING ORGANIZATION Department of Air Force Monitoring Systems Division		
6a. NAME OF PERFORMING ORGANIZATION Universal Sensors, Inc.		6b. OFFICE SYMBOL (If applicable)	7b. ADDRESS (City, State, and ZIP Code) Eglin Air Force Base, FL 31542-5320		
6c. ADDRESS (City, State, and ZIP Code) 5258 Veterans Blvd., Suite D Metairie, LA 70006		9. PROCUREMENT INSTRUMENT IDENTIFICATION NUMBER F08635-89-C-0346			
8a. NAME OF FUNDING / SPONSORING ORGANIZATION Air Force Eng. Services Center		8b. OFFICE SYMBOL (If applicable) HQAFCSC/RDVS	10. SOURCE OF FUNDING NUMBERS		
8c. ADDRESS (City, State, and ZIP Code) Tyndall AFB, FL 32403-6001		PROGRAM ELEMENT NO. 5793600	PROJECT NO. 30050054	TASK NO.	WORK UNIT ACCESSION NO.
11. TITLE (Include Security Classification) Passive Piezoelectric Hydrogen Chloride Monitor					
12. PERSONAL AUTHOR(S) Ahmad Suleiman, Marie Pender and George Guilbault					
13a. TYPE OF REPORT Final		13b. TIME COVERED FROM 7/89 TO 12/89		14. DATE OF REPORT (Year, Month, Day) 1990, January 30	
15. PAGE COUNT 25					
16. SUPPLEMENTARY NOTATION					
17. COSATI CODES			18. SUBJECT TERMS (Continue on reverse if necessary and identify by block number)		
FIELD	GROUP	SUB-GROUP	Piezoelectric Crystal Device, HCl gas		
19. ABSTRACT (Continue on reverse if necessary and identify by block number)					
<p>The purpose of this project was to develop a prototype piezoelectric crystal monitor for hydrogen chloride. The initial evaluation was to concentrate on developing selective coatings for HCl and the preliminary design of the monitor.</p> <p>A preliminary prototype PZ instrument was developed and the performance of some very promising coatings has been evaluated with respect to sensitivity, selectivity, stability, reversibility and other important analytical parameters. The proposed coatings (THEED, amine 220 and mercury) can be successfully used for the detection of low concentrations of HCl, either continuously or as a dosimeter.</p>					
20. DISTRIBUTION / AVAILABILITY OF ABSTRACT <input type="checkbox"/> UNCLASSIFIED/UNLIMITED <input checked="" type="checkbox"/> SAME AS RPT. <input type="checkbox"/> DTIC USERS			21. ABSTRACT SECURITY CLASSIFICATION Unclassified		
22a. NAME OF RESPONSIBLE INDIVIDUAL Capt. H. Williams			22b. TELEPHONE (Include Area Code) 904-283-4234		22c. OFFICE SYMBOL HQAFCSC/RDVS

## SUMMARY

A research study was conducted to develop a prototype piezoelectric crystal detector for hydrogen chloride. This study showed that a piezoelectric crystal coated with tetrakis(hydroxyethyl)ethylenediamine (THEED), amine 220 and mercury can be successfully used for the detection and determination of HCl at very low concentration ranges. The sensors exhibited good sensitivities and reproducibilities and potential to be used either continuously or as dosimeters.

A portable prototype instrument was developed that meets the criteria outlined in the Phase I proposal. The self-contained instrument features a reference and a sampling crystal, rechargeable battery, air pump and digital displays. It is 20 x 14.7 x 9 cm in dimension and weighs less than three pounds.

The proposed technology will lead to the development of piezoelectric crystal dosimeters and continuous monitoring devices for HCl and for other toxic compounds if the proper coatings are developed. The developed devices could have many applications in industrial hygiene monitoring in both military and civilian sectors.

**PREFACE:** Passive Piezoelectric Hydrogen Chloride Monitor  
U.S. Air Force Project FO8635-89-C-0346  
July 1, 1989 to December 31, 1989

by: Ahmad Suleiman, Marie Pender, and George Guilbault

**CONTRACTOR:** Universal Sensors, Inc.  
5258 Veterans Blvd., Suite D  
Metairie, LA 70006

**SPONSOR:** Headquarters Air Force Engineering and Services Center,  
Directorate of Engineering and Services Laboratory  
(HQ AFESC/RD), Tyndall Air Force Base, FL 32403-6001

**PROJECT OFFICER:** Captain Williams/RDVS/34234

**DISTRIBUTION:** HQ AFESC/RDVS 2/0  
PCO Ltr (1)  
ACO Ltr (1)

This technical report has been reviewed and is approved for publication.

## TABLE OF CONTENTS

SUMMARY.....	ii
TITLE PAGE.....	iii
TABLE OF CONTENTS.....	iv
LIST OF FIGURES.....	v
LIST OF TABLES.....	vi

### SECTION

I. INTRODUCTION	
A. Statement of problem.....	1
B. Objectives.....	2
II. EXPERIMENTAL	
A. Apparatus.....	2
B. Materials.....	3
C. Methods	
1. Coating Procedure.....	3
2. Measurements.....	4
III. RESULTS AND DISCUSSION	
A. Development of the coating.....	5
B. Effect of temperature.....	6
C. Effect of interferents.....	7
D. Analytical characteristics.....	7
E. Amalgam approach.....	8
F. Conclusions.....	9
REFERENCES.....	11

## LIST OF FIGURES

### FIGURE

1. Schematic representation of the experimental setup.....	13
2. Temperature study.....	14
3. Effect of scrubber on response time.....	15
4. Calibration plot for THEED coating.....	16
5. Calibration plot for amine 220 coating.....	17
6. Cumulative response of THEED.....	18
7. Cumulative response of THEED.....	19
8. Cumulative response of amine 220.....	20
9. Cumulative response of amine 220.....	21
10. Response of mercury coating.....	22

## LIST OF TABLES

### TABLE

1. Coating materials and response to HCl..... 24
2. The effect of amount of coating..... 25



## SECTION I

### INTRODUCTION

#### A. STATEMENT OF PROBLEM

Hydrogen Chloride is a very corrosive gas, widely used in industry for the production of several organic compounds and is a noxious by-product of certain rocket exhaust gases. The high degree of corrosiveness and toxicity justify the importance of developing a cumulative (dosimeter) sensor, as well as personal and field monitors for the detection of low levels of HCl.

Although, several techniques have been devised for the detection and determination of hydrogen chloride gas, it was pointed out that some of these techniques have serious disadvantages. In addition, selectivity was mentioned as a primary shortcoming in all of these methods (Reference 1).

In 1959, it was suggested that the piezoelectric crystal could be used as a sensing device for the measurement of the thickness of thin films, and Sauerbrey described the relationship between the mass of a film deposited on an oscillating quartz crystal and the corresponding change in the resonant frequency of the crystal (Reference 2) by the following equation:

$$\delta F = 2.3 \times 10^6 F^2 \delta M/A$$

Where  $\delta F$  = the change in frequency due to a coating (Hz),  $F$  is the resonant frequency of the piezoelectric crystal,  $A$  is the

area coated ( $\text{cm}^2$ ) and  $\delta M$  is the mass of the deposited coating. Thorough reviews of the theory and applications of piezoelectric crystal detectors in the gas phase have been presented (References 3 and 4). The potential applications of these detectors seems only to be limited by the ingenuity to develop selective coating materials. Basically, the frequency of the oscillating crystal is decreased by the adsorption of the analyte gas onto the coating; the magnitude of that decrease is proportional to the concentration of the gas.

#### **B. OBJECTIVES**

The objectives of Phase I were: 1) the development of optimum coatings useful for the detection and determination of HCl, 2) the evaluation of these coatings, and 3) the development of a preliminary prototype.

### **SECTION II**

#### **EXPERIMENTAL**

##### **A. APPARATUS**

A schematic of the instrumental set up is shown in Figure A-1. The instrumentation consisted of a low frequency mode OX transistor oscillator (International Crystal Co.) powered by a regulated power supply model IP-28 (Heath Zenith Electronics), modified by a digital-to-analog converter so that changes in the frequency of the crystal could be recorded. The piezoelectric crystals used were gold coated, 10 MHz, AT-Cut, quartz crystals

(Bliley, Erie, PA). Calibrated and bubbler flowmeters were purchased from Suppelco and Alltech Associates, respectively. Temperature monitoring was made with a digital multimeter (Radio Shack), and the relative humidity was monitored with a digital hygrometer (model HI8064, Cole Parmer Ind. Co., Chicago, IL). The various concentrations of hydrogen chloride were prepared by the permeation method. A certified hydrogen chloride permeation tube (VICI Metronics, Santa Clara, CA) and a calibration system (model 570, Kin-Tek Laboratories, Texas City, TX) were used.

## **B. MATERIALS**

Amine 220, tetrakis(hydroxyethyl)ethylenediamine (THEED) and other gas chromatography stationary phases were obtained from Alltech Associates (Deerfield, IL). Other chemicals were analytical grade reagents and used as received from commercial suppliers.

## **C. METHODS**

### **1. Coating Procedure:**

The same general coating procedure was used for all crystals. The coating material was dissolved in an appropriate solvent, then the crystals were coated by addition of known volumes of respective solutions, onto both electrodes of the piezoelectric crystal, using a microsyringe, and spreading the solution with a glass rod. The coated crystal was usually placed in an oven, at a specific temperature, depending on the coating material and the solvent, to allow the solvent to evaporate, leaving a film of coating on the surface. The amount of coating

applied to the crystal was determined by monitoring the frequency change of the crystal due to the coating.

## **2. Measurements:**

All frequency measurements were made in a flowing stream of gas at a predetermined flow rate. Base frequency measurements of the uncoated crystal were made after a stable background was established. After drying, the base frequencies of the coated crystals were remeasured to obtain a new base frequency shift as a result of the coating. In either of these two cases, only pure background gas was allowed to come in contact with the crystal.

for actual sample measurements, the coated crystals were allowed to come to a stable baseline in the pure background carrier gas. To make a measurement, a four-port valve was used to redirect the sample vapors to the crystal chamber. Changes in frequency were recorded every 30 seconds as the sample continuously flowed past the crystal, for two minutes, before switching back to the pure background carrier gas. To repeat a measurement, a five minute recovery period was needed for the crystal to return to the pre-sample introduction frequency and also to purge the system of any sample that might be in the crystal chamber.

At the beginning of each day, the system was purged with the vapors saturated with the sample, to minimize the absorption of sample by the different components of the generation system. Initially, a single crystal chamber made from glass was used. Then a new chamber made from polycarbonate (Lexan) was designed

to hold two crystals and to provide the same degree of exposure to the substrate. In the final stages, the exposure chamber was replaced with a two liter glass round bottle fitted with two side inlet and outlet Swagelok fittings for sampling gas introduction and evacuation.

The neck of the bottle was fitted tightly with a teflon block which encapsulated two thin stainless steel rods. Two sockets were soldered to the ends of both rods to provide an easy way to connect or remove the piezoelectric crystal.

For passive measurements, the bottle was first evacuated, then a stream of the sampling gas with a known HCl concentration was allowed to flow through for two hours at a flow rate of 100 mL/min. The flow rate was then decreased to 5 mL/min to eliminate the effect of flow rate on the response, compensating at the same time for possible adsorption of the HCl onto the glass. The coated crystal was then mounted on the teflon block and its frequency was monitored versus time.

### **SECTION III**

#### **RESULTS AND DISCUSSION**

##### **A. DEVELOPMENT OF THE COATING**

An extensive study was conducted to evaluate possible coating materials. Inorganic salts of mercury, copper and silver, as well as several organic and organometallic compounds and gas chromatographic stationary phases were tested. Table B-1

shows a partial list of these coatings and their responses. The highest response was obtained using the coatings amine 220, THEED and Carbowax 1000 monostearate. Subsequent studies were conducted, largely using THEED and, to a lesser extent, amine 220.

A set of experiments was performed to determine the amount of THEED coating to be applied to the crystal. It is evident from Table B-2 that the response increases as the amount of coating increases, because of an increased probability of interaction between the coated material and the HCl molecules. However, higher amounts of coatings overloaded the crystal and impaired the vibration. Generally, if high amounts of coatings are used, it is difficult to obtain a uniform dry film which results in poor precision and longer recovery times. It was determined that, for both good response and reproducibility, an amount of coating which causes a decrease of about 16,000-25,000 Hz in the crystal frequency is sufficient.

#### **B. EFFECT OF TEMPERATURE**

Figure A-2 shows the effect of temperature on the response of the detector. In this study, the carrier gas was passed through a coil which was placed in a thermostated bath and the exposure chamber was wrapped with a heating tape to obtain a constant temperature. The adsorption of HCl by the coating and the sensitivity decreased as the temperature increased. However, the magnitude of the response at about 40°C is still large enough to perform useful analysis pending recalibration.

### **C. EFFECTS OF INTERFERENTS**

Several inorganic and organic potential interferents, which would be expected to exist in combat areas and around launch sites, were tested. The effects of water, benzene, toluene and sulfur fumes were tested by a continuous process method. Other gases, including  $\text{NH}_3$ ,  $\text{CO}$ ,  $\text{H}_2\text{S}$ ,  $\text{COCl}_2$ ,  $\text{SO}_2$  and auto exhaust were tested by the syringe dilution method. Water and very high concentrations of benzene, toluene and sulfur dioxide caused high frequency changes in comparison to these obtained for  $\text{HCl}$ . To improve the detector selectivity, a major effort was directed to eliminate the effect of moisture which was the most troubling factor. Several approaches were evaluated, using several desiccants, molecular sieves and hydrophobic membranes. It was concluded that magnesium perchlorate can be used to eliminate the effect of moisture and other interferents without seriously affecting the sample integrity and the response. Although, the use of the scrubber increases the response time (Figure A-3), it is possible to increase the flow rate to decrease the response time if desired, as in the case of continuous monitoring.

### **D. ANALYTICAL CHARACTERISTICS**

Typical calibration plots of frequency change versus concentration are shown in Figure A-4 and A-5 using THEED and amine 220 coatings, respectively. Both plots were linear in the concentration range of 1.5 - 9.5 ppm (V/V) of  $\text{HCl}$ , and exhibited good linearities ( $r^2 = 0.992$  for THEED;  $r^2 = 0.950$  for amine

220). The concentration range studied was limited by the permeation tube and the generation device used, and it should be possible to measure higher or lower concentrations by varying the sampling time. The feasibility of using the coated crystals as a cumulative (dosimeter) sensor was next investigated. The responses of the two coated crystals versus time at two different HCl concentrations are shown in Figures A-6, A-7, A-8 and A-9. Although, this study was not completed due to time limitations, there seems to be a definite relation between the concentration of HCl in the sample and the exposure time. All parameters affecting the performance of the cumulative sensor will be optimized in Phase II. The useful lifetime of a single coating was more than five weeks (approximately 500 assays) without significant loss in sensitivity. The useful shelf lifetime of a single coating was checked periodically over a period of five months. It was concluded that a coated crystal could be stored for even longer periods and still be used with remarkable reproducibility.

#### **E. AMALGAM APPROACH**

The use of elemental mercury as a coating offers a very promising alternative especially since the effects of moisture and other interferences can be significantly minimized, if not eliminated. Several gold coated crystals were exposed to mercury vapors and amalgam films were formed. A representative plot of response versus time is shown in Figure A-10. The initial study shows that this approach is quite promising and useful in



developing both continuous and cumulative type detectors for HCl. It is noteworthy to mention that one crystal exhibited only a 2 Hz natural drift over two hour period, while the same crystal was used for three consecutive determinations without regeneration at sampling times of seven minutes with good reproducibility. This approach should be further investigated in Phase II.

#### **F. CONCLUSIONS**

A piezoelectric crystal coated with THEED or amine 220 possesses good sensitivity, reversibility, reproducibility and selectivity for the continuous active and passive monitoring of HCl. Additionally, a mercury coated crystal seems even to hold more promise and will probably exhibit better analytical characteristics as a dosimeter sensor. All of these exciting possibilities will be followed up in Phase II and optimized systems developed.

In Phase II, the current technology will be redesigned in order to reduce the size of the prototype developed in Phase I to that of a portable continuous monitor and a badge type detector. Both instruments will have memory capabilities in order to give concentration versus time profiles (continuous) as well as total dosage (dosimeter). The final design of the monitor dosimeter will be similar in shape to a radiation badge housing a piezoelectric crystal to be worn by concerned personnel or a small assembly, to be mounted at selected locations. The frequency of the crystal can be monitored at any time by plugging

the badge into a readout unit. Also, the final unit will be miniaturized and microprocessor memory capabilities will be incorporated. Calibration curves of frequency change ( $\delta F$ ) versus gas concentration will be established by actual exposure experiments and will be programmed into the monitor microprocessor to obtain total concentration readout.


The program outlined will lead to the development of devices which could be useful to many government agencies and could have several commercial applications.

## REFERENCES

- 1) Gregory, G.L., Measurement Techniques Investigated For The Detection Of Hydrogen Chloride In Ambient Air, NASA. TND-8352, 1976.
- 2) Sauerbrey, G.Z., "The Use Of Oscillators For Weighing Thin Layers And For Microweighing", Z. Phys., 155, 206-12, 1959.
- 3) Guilbault, G.G. and Jordan, J.M., "Analytical Uses Of Piezoelectric Crystals", Critical Reviews In Analytical Chemistry, 19, (1), 1-28, 1988.
- 4) Alder, J.F. and McCallum, J.J., "Piezoelectric Crystals For Mass And Chemical Measurements", Analyst, 108, 1169-89, 1983.

APPENDIX A  
FIGURES


**FIGURE 1**  
**SCHEMATIC REPRESENTATION OF THE EXPERIMENTAL SETUP**



1) Silica gel column; 2) flow meter; 3) humidity source; 4) four-way valve; 5) hygrometer; 6) column; 7) test cell; 8) temperature control; 9) power supply; 10) oscillator; 11) frequency counter; 12) digital-to-analog converter; 13) recorder.

FIGURE 2


## Temperature Study



$C_{HCl} = 9.4$  ppm; Flow Rate = 100 mL/min; Coating = THEED

FIGURE 3

EFFECT OF SCRUBBER ON RESPONSE TIME



$C_{HCl} = 8$  ppm; (a) Flow Rate = 40 mL/min; (b) Flow Rate = 20 mL/min

FIGURE 4

CALIBRATION PLOT FOR THEED COATING






FIGURE 5





FIGURE 6


# CUMULATIVE RESPONSE OF THEED



$C_{HCl} = 9.4 \text{ ppm}$

FIGURE 7


# CUMULATIVE RESPONSE OF THEED



$C_{HCl} = 4.5 \text{ ppm}$

FIGURE 8


# CUMULATIVE RESPONSE OF AMINE 220



$C_{HCl} = 4.5 \text{ ppm}$


FIGURE 9

# CUMULATIVE RESPONSE OF AMINE 220



$C_{HCl} = 9.4 \text{ ppm}$

FIGURE 10



$C_{HCl} = 8 \text{ ppm}$

**APPENDIX B**

**TABLES**

TABLE 1

COATING MATERIALS	RESPONSE TO HCl (Hz)
Carbowax 1000 Monostearate	42.00
Cyanethyl Sucrose	15.80
N,N - Bis (2-cyanoethyl) Foramide	30.00
B,B Thiodipropic Nitrile	21.30
Triethanolamine	28.00
Versamide 90	10.20
Tergitol NPX	32.00
Ucon LBL - 300X	19.25
1,6 Hexane Diol Dimethylacrylate	0.00
AT 220	39.00
Apiezon J	20.25
Ethylene Glycol Adipate	34.40
GPIII Ucon	25.80
Tween 80	23.40
THEED	67.00
Trimethylamine HCl	12.60
Armeen 25	6.00
2,3 - Diaminonaphthalene	Unsuitable
N,N' Bis (2-hydroxyethyl) ethylene diamine	19.40
AT 1200	0.00
Phenyl diethanolamine succinate (PDEAS)	12.00

$C_{HCl} = 8.0 \text{ ppm}$ ; Flow Rate = 100 mL/min



TABLE 2  
THE EFFECT OF AMOUNT OF COATING

AMOUNT OF COATING (Hz)	RESPONSE (Hz)
14331	61
16778	116
19258	92
19823	101
20851	82
23013	132
24142	123

$C_{HCl} = 8$  ppm; Flow Rate = 100 mL/min; Coating = THEED